


**Government Engineering Department**  
**Combined Grading for RCC Work**  
 Quality Control Laboratory  
 District-Rangpur

Sieve Size (mm)	% Passing		% Passing Considered		Combined % Passing	Specified % Passing
	Sample # 1 25mm Down Stone Chips	Sample # 2 12mm Down Stone Chips	Sample # 1	Sample # 2		
25.00	100.00	100.00	60	40	100	100
19.00	90.80	100.00	54	40	94	90-100
9.50	24.50	58.00	15	23	38	20-55
4.75	2.50	10.00	2	4	6	0-10
2.360	1.55	2.00	1	1	2	0-05

100	100	100
90	94	100
20	38	55
0	6	10
0	2	5



Construction of Approach road of 301.00m Long PSC Girder Bridge over Kartoa river at Nundaha ghat ch-4500m, Pirganj-Upazila, Dist-Rangpur.  
 Package No-CIB-Ran-W-27b  
 Contractor Name-Barendra Construction, Rajshahi  
 Date of Test- 16/06/2025

25mm Down Stone Chips - 60%  
 12.5mm down Size Stone Chips - 40%

Signed by-

*Anur*  
 26/06/25  
**Md. Anarul Islam**  
 Sub-Assistant Engineer (Lab)  
 LGED, Rangpur

*[Signature]*  
 26/06/25  
**Assistant Engineer**  
 LGED, Rangpur.

**Senior Assistant Engineer**  
 LGED, Rangpur.